



ADDENDUM NUMBER TWO FOR CONTRACT NUMBER FY2014-02

DATE: June 18, 2013

TO: ALL BIDDERS OF RECORD

BID FOR: BIG TURTLE DOG PARK - ENTRY STRUCTURE, SIGN STRUCTURE & SIDEWALK

This addendum forms a part of and modifies the bid specifications for the above item currently scheduled to open June 27, 2013 at 2:00 p.m. (local time) at the City of Oak Ridge, Central Services Complex, 100 Woodbury Lane, Oak Ridge, Tennessee.

CLARIFICATIONS FROM PRE-BID CONFERENCE

ITEM 1 – Questions, Comments and Requests for Clarification received from Bidders

- A. **Comment:** The specifications call for welded wire fabric reinforcing in the new sidewalks. However, only the spacing pattern for the fabric is provided (6x6). Please provide the wire gauge size. Otherwise, we will assume that it is WWF6x6x10/10.

Response: WWF6x6x10/10 – correct

- B. **Comment:** The drawings show steel base plates with anchor bolts for the entry and sign structures. However, the base plate size(s) are not specified. Please provide the size(s). Otherwise, we will assume 15"x15"x1/2" and 12"x12"x1/2" steel base plates for the entry and sign structures respectively.

Response: 15"x15"x1/2" and 12"x12"x1/2" are correct

- C. **Comment:** The foundations for the entry sign have two layers of rebar reinforcing ("T&B"). However, the sign structure only has one layer of bottom reinforcing. Please confirm or otherwise advise.

Response: Both should have two layers.

Please contact Lyn Majeski, City of Oak Ridge Finance Department, at lmajeski@oakridgetn.gov with any questions concerning this addendum.