



**ADDENDUM NUMBER ONE  
FY2023-012**

**DATE:** August 5, 2022  
**TO:** ALL BIDDERS OF RECORD  
**FROM:** Lyn Majeski, Purchasing Manager  
**BID FOR:** **Fire Station No. 4 HVAC Repairs**

This addendum forms a part of and modifies the bidding specifications for the above item for the City of Oak Ridge, Tennessee.

**ITEM 1 – Changes to Invitation to Bid,**

1. Page 1 of 5, Discrepancies, last sentence change to:

All questions must be submitted to Lyn Majeski in writing before 9:00 AM, local time, on August 9, 2022.

**ITEM 1 – Comments/Questions Received from Potential Bidders**

1. Drawing M1, are we to reuse the existing 10 inch outside air duct for connection to the new DD? Current site conditions it appeared that this existing duct would be reusable.

The drawings show new 10" OA ductwork at both connections to the DD but the existing 10" OA may be reused provided the existing ductwork is relocated as (if required to provide straight runs of duct.

2. Drawing M1 Condensate calls for PVC on the condensate, is this not a rated ceiling area? Please confirm.

The ceiling is fire rated (hence the use of new air distribution devices with fire dampers). The space above the fire rated ceiling is not a return air plenum & thus PVC can run in that space. The intent is to run PVC condensate to existing condensate lines above the ceiling so a ceiling penetration with PVC is not required.

3. Assume all work to be preformed during normal business hours?

Yes, 8:00 A.M. to 5:00 P.M.

**\*\*Acknowledge receipt of this addendum when you submit your Bid\*\***