



# Oak Ridge Fire Department

## Fire Prevention Division

P.O. Box 1  
Oak Ridge, TN 37831  
(865) 425-3524  
Fp1@oakridgetn.gov

**\*\*\*Effective June 21<sup>st</sup>, 2019\*\*\***

### **The following codes will be in effect:**

**2018 International Fire Code**  
2018 International Building Code  
2018 International Mechanical Code  
2018 International Residential Code  
2018 International Plumbing Code  
2017 National Electric Code

Please direct any questions concerning the above codes that are not in bold to Community Development Codes Enforcement at 865-425-3532.

### **Upon issuance, any NFPA Standards that are referenced in the above codes will be used, including but not limited to the following.**

**NFPA 13 Standard for the Installation of Sprinkler System (2019 edition)**  
**NFPA 13R Standard for the Installation of Sprinkler Systems in Low-rise Residential Occupancies (2019 Edition)**  
**NFPA 14 Standard for the Installation of Standpipe Hose Systems (2019 edition)**  
**NFPA 20 Standard for the Installation of Stationary Pumps for Fire Protection (2019 edition)**  
**NFPA 72 National Fire Alarm and Signaling Code (2019 edition)**

### **Additional Requirements**

**Buildings over 7,500ft<sup>2</sup> (unless required elsewhere in the above code) will be required to have an Automatic Fire Sprinkler System including Fire Alarm System.**

**Buildings over 5,000ft<sup>2</sup> (unless required elsewhere in the above code) shall be provided with a listed fire alarm system.**

**Fire alarm control panel or fire alarm remote annunciator must be located at the main entrance or other approved location by the fire official.**

**If there are any questions, please feel free to call.**