

All Plants and landscaping must not be located within 5-feet in all directions (180 degrees) to the sides and back of the fire hydrant, so that at maturity the plants will not obstruct the hydrant within 3 –feet sides and rear. From the middle of the side discharge of the hydrant to the curb (15-feet in both directions) no planting or other landscaping shall obstruct the fire hydrant from access to the road.

